

SAFE DRINKING WATER CERTIFICATE

No. 24

Dated: 24/02/26

It is certified that an inspection team headed by Satya Prakash Azad (Chemist) (Name of Officers with designation) from P.H.E.D. Investigation Office (Name of Department/ Office) inspected the Kids Camp International School, Naruli Sen Binda, Musahari Muzaffarpur, Bihar 843119 (Name & Address of the school) on 20.02.2026 date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **One year**

Signature with Seal:

Name

Designation:

S.P.A.
24/02/26
CHEMIST
R.W.T.L; MUZAFFARPUR

To
The Principal,
Kids Camp International School,
Naruli Sen Binda,
Musahari Muzaffarpur, Bihar 843119

Shoukat Ali
Manager
Kids Camp International School
Narauli Sen, Binda
Muzaffarpur (Bihar)

Rupali
Principal
Kids Camp International School
Narauli Sen, Binda
Muzaffarpur-843119

PUBLIC HEALTH ENGINEERING DEPARTMENT

Regional Water Testing Laboratory

Month - February 2026

District Name : Muzaffarpur

Sl. No	Block	Panchayat	Village	Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	NO ₃	F	As	MPN	Remarks
1	Musaheri	Narauli	Narauli Sen Binda		Kids Camp International School	6.98	1	240	188	118	87.28	11.08	24	110	0.3	15	5	1.0 ppm	BDL	NIL	
					Acceptable Limit (IS 10500-2012)	6.5-8.5	1 NTU		500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	45 mg/l		0.01 ppm	0.01 mg/l	
					Permissible Limit in absence of alternate source (IS 10500-2012)	NR	5 NTU		2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	NR	1.5 ppm	NR	0.1 mg/l	

Rupali
Principal
Kids Camp International School
Narauli Sen, Binda
Muzaffarpur-843119

Chandru Kumar
Manager
Kids Camp International School
Narauli Sen, Binda
Muzaffarpur (Bihar)

S. P. S.
Chemist
29/02/26
RWTL Muzaffarpur
CHEMIST
843119-843119